

**Harcros Pigments Inc.**

2001 Lynch Avenue  
East St. Louis, IL 62205  
Telephone (618) 271-4700  
FAX (618) 375-5081



*Beerb*

**HARCROS**

PIGMENTS

EPA Region 5 Records Ctr.



390916

**CERTIFIED MAIL**

**October 2, 1990**

Director, Water Division  
U. S. Environmental Protection Agency  
Region V  
230 South Dearborn Street  
Chicago, IL 60604  
Attention: Compliance Section, 5WQC-TUB-8

Chief, Compliance Assurance Section  
Illinois Environmental Protection Agency  
Department of Water Pollution Control  
2200 Churchill Road  
Springfield, IL 62706

**RECEIVED**  
Compliance Assurance Section  
OCT 04 1990  
Environmental Protection Agency  
STATE OF ILLINOIS

Re: Clean Water Act Sec. 308 Request V-W-90-308-11

Gentlemen:

Attached, pursuant to the Section 308 request cited above, are flow measurements of discharges by the Harcros Pigments Company facility in East St. Louis, Illinois, to sanitary sewers leading to the American Bottoms Regional Wastewater Treatment facility (ABRWTF) during September, 1990. These measurements are recorded by employees of Harcros. Please note that flow measurements are also recorded from the same devices by ABRWTF employees. We have not yet received from ABRWTF its measurements for September, 1990 but will send you a copy of them when we receive them if you so desire. They both represent measurements recorded at the same flow measurement devices. These two sets of measurement may be somewhat different, however, because they were recorded at different times during the day. Harcros records measurements at approximately 7:00 a.m., whereas ABRWTF records them somewhat later.

For September 18 through 30, the Southwest Sewer Flowmeter was not functioning. The average flow value for the month of 169,000 gallons was used during this period. Aside from this period, the flows represented are to the best of my knowledge and belief the measurements recorded by Harcros personnel, were the measurements

observed by them and represent actual flows within the normal range of accuracy of the type of flow meter utilized.

Very truly yours,

*Dennis M. Valentino*  
Dennis M. Valentino  
Director of Operations

County of St. Clair  
State of Illinois

Sworn and subscribed before me this 6th day of September, 1990.

*Denise Malsby*  
Notary Public

Attachments

rm

"OFFICIAL SEAL"  
Denise Palsenberger  
Notary Public, State of Illinois  
St. Clair County  
My Commission Expires 12/1/90

**RECEIVED**  
Compliance Assurance Section  
OCT 04 1990  
Environmental Protection Agt.  
STATE OF ILLINOIS

in 10 <sup>6</sup> Gallons	Flow	Flow	WM
1	.361	.202	0
2	.326	.498	0
3	.427	.168	0
4	1.765	.161	.001
5	1.297	.150	0
6	1.949	.156	0
7	1.535	.062	0
8	1.373	.136	0
9	.545	.138	0
10	1.208	.240	0
11	.992	.147	0
12	.951	.182	0
13	1.116	.124	0
14	1.678	.166	0
15	1.666	.108	0
16	1.944	.128	0
17	1.616	.116	0
18	2.111	Not Functional	0
19	1.878		0
20	2.116		.005
21	2.052		0
22	1.678		0
23	.645		0
24	1.651		0
25	2.003		0
26	2.078		0
27	1.777		0
28	1.617		0
29	1.818		0
30	1.743		0

**RECEIVED**  
 Compliance Assurance Section  
 OCT 04 1990  
 Environmental Protection Agency  
 STATE OF ILLINOIS